

कार्यालय-चिकित्सा अधिकारी प्रभारी राजकीय सामुदायिक स्वास्थ्य केन्द्र

कटकड़, ब्लॉक श्रीमहावीरजी, जिला-करौली (राजस्थान)

प्रेषक-

चिकित्सा अधिकारी प्रभारी
राजकीय सामुदायिक स्वास्थ्य केन्द्र
कटकड़, ब्लॉक-श्रीमहावीरजी, जिला-करौली (राज.0)



प्रेषित :-

श्रीमान् -
Royal International
School, Kheda.

क्रमांक : 830/2024-25

दिनांक 12/7/24

SAFE DRINKING WATER AND SANITARY CERTIFICATE

It is certified that an inspection team headed by DR.BABLESH MEENA (MEDICAL OFFICER) from COMMUNITY HEALTH CENTER , KATKAD inspected ROYAL INTERNATIONAL SCHOOL, kheda on 12/7/24 and on the basis of water test report (Attached) bearing no 49/2024-25 dated 29/04/24 of PHED, KARAU LI certified that ROYAL INTERNATIONAL SCHOOL has safe drinking water facilities for the students and staff members of the institution. School also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by central/ state /U.T Govt.

B. Bablesh
चिकित्सा अधिकारी
प्रधान चिकित्सक
सामुदायिक स्वास्थ्य केन्द्र
कटकड़ (करौली)

Signature with seal....

Name Dr. BABLESH MEENA
Designation Medical officers.

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, KARAU LI

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Jr. Chem./2024-25/ 49


Date-29.04.24


To,
PRINCIPAL
ROYAL INTERNATIONAL SCHOOL
KHEDA

Particulars	Source		drinking water
	Location		Royal International School Kheda
Block			Hindaun city
Village/Town			Hindaun city
Date of Collection			29.04.24
Date of receipt			29.04.24
Date of Examination			29.04.24
Sample No			P1
	Permission value as per		
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	
1. pH	6.5-8.5	6.5-8.5	6.9
2. Turbidity (NTU)	1	5	0.5
3. Colour (Hazen Units)	5	15	
4. Odour	Un Objectionable		
5. Total Alkalinity (as CaCo ₃) mg/l	200	600	130
6. Total Hardness (as CaCo ₃) mg/l	200	600	120
7. Chloride (as Cl ⁻) mg/l	250	1000	110
8. Sulphate	200	400	
9. Fluoride mg/l	1	1.5	0.72
10. Nitrate	45	No relaxation	20
11. Iron	0.3	No relaxation	
12. Arsanic	0.1	0.05	
13. Total dissolved solids	500.0	2000	448

1. SAMPLE FOUND SATISFACTORY

2. Water is clean and Safe to drink


 Pawan Kumar Sharma
 Junior Lab Assistant
 Phed Lab Karauli


 (Vijay Singh Meena)
 Junior Chemist
 P.H.E.D. Laboratory, karauli